



Ref. Certif. No.

**SE-109470**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### CB TEST CERTIFICATE

Product	Switch-disconnector
Name and address of the applicant	Zhejiang GEYA Electrical Co.,Ltd Wenzhou Brige Industrial Zone,Beibaixiang, Yueqing City, Zhejiang, China
Name and address of the manufacturer	Same as applicant
Name and address of the factory	Same as applicant
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	Ue= 230V~(1P), 400V~(2P, 3P, 4P), 50Hz; Ie= 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A; Ui= 690V, Uimp= 4kV; Icw= 3kA/1s, Icm= 4,26kA, Cat. AC-22A.
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	GYH08
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	221000246SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

Date: 07 November, 2022

Signature:

Quan Li



Ref. Certif. No.

**SE-109470**

### **Additional information**

Explanation of type designation LJSF\*-\*:

1st \* denotes the number of poles: 110 for 1P, 210 for 2P, 310 for 3P, 410 for 4P;

2nd \* denote the rated operational current  $I_e$  without "A": 16, 20, 25, 32, 40, 50, 63, 80, 100, 125.

Date: 07 November, 2022

Signature:

A handwritten signature in black ink, appearing to read 'Anam Li'.